



NOTE: THESE CLEARANCES ARE UCES MINIMUMS. GREATER CLEARANCES MAY BE REQUIRED BY CODES, DUE TO BUILDING CONSTRUCTION, TYPE OF TRANSFORMER, LOCATION OF DOORS AND WINDOWS, ETC. CONSULT WITH UCEA.



CLEARANCE DETAIL
FOR PAD MOUNTED TRANSFORMER

DATE: 02/09/2017

DRAWN: Kevin Ferguson